



ARIZONA DE  
CERTIF

DRAINING WATER WELL FACILITIES



0000122836

JALITY  
T

W-02386A-09-0308  
W-02386A-09-0554

ORIGINAL

Page 1 Of 1

<b>ADEQ File No:</b> 20100213		<b>LTF No:</b> 53392	
<b>System Name:</b> Sun Leisure Estates Util		<b>System Number:</b> 14-075	
<b>Project Owner:</b> Sun Leisure Estates Utilities Co., Inc			
<b>Address:</b> P O Box 1074, Yuma, AZ 85366			
<b>Project Location:</b> Yuma		<b>County:</b> Yuma	
<b>Description:</b> CONSTRUCT A NEW POTABLE WATER WELL, SUN LEISURE ESTATES WELL NO. 3, ADWR NO. 55-220070. WELL PUMPS UP TO 130 GPM AND IS 240 FEET DEEP.			

**Approval to construct the above-described facilities as represented in the approved documents on file with the Arizona Department of Environmental Quality is hereby given subject to provisions 1 through 4 continued on page 1 through 1**

1. This project must be constructed in accordance with all applicable laws, including Title 49, Chapter 2, Article 9 of the Arizona Revised Statutes and Title 18, Chapter 5, Article 5 of the Arizona Administrative Code.
2. Upon completion of construction, the engineer shall fill out the Engineer's Certificate of Completion and forward it to the Southern Regional Office located in Tucson. If all requirements have been completed, that unit will issue a Certificate of Approval of Construction. R18-5-507(B), Ariz. Admin. Code. At the project owner's request, the Department may conduct the final inspection required pursuant to R18-5-507(B); such a request must be made in writing in accordance with the time requirements of R18-5-507(C), Ariz. Admin. Code.
3. This certificate will be void if construction has not started within one year after the Certificate of Approval to Construct is issued, there is a halt in construction of more than one year, or construction is not completed within three years of the approval date. Upon receipt of a written request for an extension of time, the Department may grant an extension of time; an extension of time must be in writing. R18-5-505(E), Ariz. Admin. Code.
4. Operation of a newly constructed facility shall not begin until a Certificate of Approval of Construction has been issued by the Department. R18-5-507(A), Ariz. Admin. Code.

Reviewed by : NLS

By: Janak K. Desai  
Janak K. Desai, P.E. Unit Manager

1/24/2011  
Date

cc: File No : 20100213  
Regional Office: Southern  
Owner: Sun Leisure Estates Utilities Co., Inc  
County Health Department: Yuma  
Engineer: Yuma Territorial Eng.  
Planning and Zoning/Az Corp. Commission  
Engineering Review Database - Etr022

Engineering Review Section  
Water Quality Division

Arizona Corporation Commission

DOCKETED

FEB 3 2011



ARIZONA CORPORATION COMMISSION  
DOCKET CONTROL

2011 FEB - 3 P 3: 53

RECEIVED